

# NH2XLPV 1500V DC 63A-400A

## Photovoltaic Fuse

### 光伏熔断器

Standard/ UL 248-19

INTERRUPTING CAPACITY/  
30,000 A at 1500V DC

TECHNICAL PARAMETERS/ :

PART NO. 目录编号	CURRENT RATING 额定电流	SAFETY APPROVALS 安全认证
		cULus
2XLPV63U15A/A2	63A	●
2XLPV63U15B/BC		●
2XLPV80U15A/A2	80A	●
2XLPV80U15B/BC		●
2XLPV100U15A/A2	100A	●
2XLPV100U15B/BC		●
2XLPV125U15A/A2	125A	●
2XLPV125U15B/BC		●
2XLPV160U15A/A2	160A	●
2XLPV160U15B/BC		●
2XLPV200U15A/A2	200A	●
2XLPV200U15B/BC		●
2XLPV250U15A/A2	250A	●
2XLPV250U15B/BC		●
2XLPV315U15A/A2	315A	●
2XLPV315U15B/BC		●
2XLPV350U15A/A2	350A	●
2XLPV350U15B/BC		●
2XLPV400U15A/A2	400A	●
2XLPV400U15B/BC		●

A- 触刀安装带中央指示器 blade contacts with the center indicator  
A2- 触刀安装带中央指示器和顶部指示器 blade contacts with the central indicator and the top indicator  
B- 螺栓连接 bolted connections  
BC- 螺栓连接带微动开关底座 bolted connections with microswitch base  
A、A2-optional 可选择  
B、BC-optional 可选择

U15 DENOTES FOR 1500V DC

U15 表示 1500V DC

● DENOTES FOR APPROVAL

● 表示已取得安全认证

○ DENOTES FOR PENDING

○ 表示正在申请安全认证

NH2XLPV 1500V 平均 I-T 曲线图 (仅供参考)

AVERAGE I-T CHARACTERISTICS CURVE  
(FOR REFERENCE ONLY)

TIME(s)/ 时间 (秒)

CURRENT(A)/ 电流 (安培)